



**INVITATION TO BID #16-041
WINDSOR PARKWAY PEDESTRIAN
SIDEWALK AND BRIDGE PROJECT**

**Bid Due Date
June 23, 2016; 2:00 p.m.
City of Sandy Springs
Purchasing Office
7840 Roswell Road, Building 500
Sandy Springs, GA 30350**

**COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB.
City of Sandy Springs – Purchasing Division
Sandy Springs City Hall
7840 Roswell Road Bldg. 500
Sandy Springs, GA 30350**

NOTE: Detectable warning surface to be cast in place per GDOT specifications, color to be determined.

QUESTIONS/RESPONSES

- 1. The plans and specs do not state the Load capacities for the HELICAL PIERS or if the conversion to HELICAL PIERS from H-Piles was made. I went to addendum 1- 534.2 and there are no Compression load capacities shown or if HELICAL PIERS are required. Without the KIPS or load capacities and a drawing or spec showing HELICAL PIERS I won't be able to send you a price quote. If you can please send the compression load capacity for the HELICAL PIERS? Helical piles are not approved, and the bid should be based on the plans, as stated in addendum 1."**
- 2. I also never got a response about helical piles. If the engineer substitutes the H-Piles to HELICAL PIERS, could we quote this item as Helical Piers rather than H-Piles? Substitution of helical piles is not approved for this project.**

I hereby acknowledge receipt of Addendum Number 2 for #16-041 Windsor Parkway Pedestrian Sidewalk and Bridge Project and have incorporated the changes into my response for the abovementioned Invitation to Bid.

COMPANY NAME: _____
CONTACT PERSON: _____
ADDRESS: _____ **CITY:** _____ **STATE:** _____
ZIP: _____ **PHONE:** _____
EMAIL ADDRESS _____
SIGNATURE: _____ **DATE:** _____